

### Sensor Installation


- 1 Pull the battery tab to activate the sensor.



- 2 Ensure the mounting surface is clean.
- 3 Peel off the adhesive backing.



- 4 Mount the sensor at the desired location and apply light pressure for 2 seconds to ensure proper adhesion.
- ⊗ Sensor should be placed **at least 1 m (3ft)** from doors, windows, air supply, air vents or any other heating or cooling source that can affect the temperature or humidity measurement.




For support and more information about our products, visit: [d21s.com/support](https://d21s.com/support)

**Disruptive Technologies Research AS**  
Strandveien 17, 1366 Lysaker, Norway

TM and © Disruptive Technologies  
Research AS. All rights reserved.

Designed and manufactured in Norway.



**Safety & Use**  
**Manual**



**Keep sensors, containing batteries, out of reach of children.**  
Seek medical assistance immediately in case of ingestion.

## Please read this guide before attempting to operate the product

Failure to follow these instructions may result in an increased risk of personal injury or damage to property, including through fire, electrical shock, burns or suffocation.

Disruptive Technologies Research AS shall not be liable for damage caused where the product owner has failed to follow the instructions set out in this guide.

No changes shall be made to the equipment without the manufacturer's permission as this may void the user's authority to operate the equipment.

### Temperature & Humidity Sensor (EU Version):

Frequency Band ISM 868 MHz  
Transmit Power < 10 mW

**CE:** Hereby, Disruptive Technologies Research AS declares that the radio equipment type Wireless Temperature & Humidity Sensor PN 102892 is in compliance with Directive 2014/53/EU. The full text of the EU declaration of conformity is available at the following internet address: [www.d21s.com/doc](http://www.d21s.com/doc)

**UK:** Hereby, Disruptive Technologies Research AS, declares that the radio equipment type Wireless Temperature & Humidity Sensor PN 102892 is in compliance with UK SI 2017, No 1206: Radio Equipment Regulations. The full text of the UK DoC can be found at the following web address: [www.d21s.com/doc](http://www.d21s.com/doc)

### Temperature & Humidity Sensor (US Version):

Frequency Band ISM 915 MHz  
Transmit Power < 10 mW

**FCC:** This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This device complies with the safety requirements for portable RF exposure in accordance with FCC rule part 52.1093 and KDB 447498 D01.

### Operating Conditions

Temperature: -40°C to 85°C (-40°F to 185°F)  
Humidity: 0 to 100%RH (non condensing)

### Recommended Storage Conditions

Cool and dry, near normal room temperature.

### Warnings

- For professional use only.
- Should not be installed in a location where it will be accessible to small children.
- Not waterproof, should only be used in a dry environment.
- Only use BR1632A battery. Note the polarity (orientation) of the battery as indicated on the device.
- Do not crush, cut, disassemble or dispose of batteries in fire. It can result in an explosion or leakage of harmful and flammable substances.
- Do not expose batteries to temperatures above 85°C (185°F) or extremely low air pressure due to risk of rupture or explosion.

**ISED:** This device contains licence-exempt transmitter(s)/ receiver(s) that comply with Innovation, Science and Economic Development Canada's licence-exempt RSS(s). Operation is subject to the following two conditions:  
(1) This device may not cause interference  
(2) This device must accept any interference, including interference that may cause undesired operation of the device

Cet appareil contient des émetteurs / récepteurs exemptés de licence conformes aux RSS (RSS) d'Innovation, Sciences et Développement économique Canada. Le fonctionnement est soumis aux deux conditions suivantes:

- (1) Cet appareil ne doit pas causer d'interférences
- (2) Cet appareil doit accepter toutes les interférences, y compris celles susceptibles de provoquer un fonctionnement indésirable de l'appareil

This device complies with the safety requirements for RF exposure in accordance with RSS-102 Issue 5 for portable use conditions.

Le présent appareil est conforme aux limites d'exposition aux RF conformément au norme CNR-102 émission 5 pour conditions d'utilisation portable.